WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

438700

County Stark Township Perry Section of Township

Owner Wm McDonald Address Canton

Location of property 5457 Navarre St

CONSTRUCTION DETAILS

Casing diameter 4" Length of casing 26

Type of screen Length of screen

Type of pump

Capacity of pump

Depth of pump setting

Date of completion

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 12 G.P.M. Duration of test 1 hrs

Drawdown 8 ft. Date 11-13-72

Static level-depth to water 58 ft.

Quality (clear, cloudy, taste, odor) Clear

Pump installed by

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Soft Brownshale	0 Feet	29 Ft.
Greyshale	29	31
Limerock	31	34
Greyshale	34	90
Limerock	90	92
Greyshale	92	118

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm J. J. Skolnik Date 12-6-72

Address Magnolia O Signed J. J. Skolnik

*If additional space is needed to complete well log, use next consecutive numbered form.