

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

439566

OK

County Marion Township Bennington Section of Township _____
Owner Dean Hollander Address 3841 Pega Ave Col. O.
Location of property Bennington Twp. Rd 21

CONSTRUCTION DETAILS

Casing diameter 6.0 D Length of casing 280
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

BAILING OR PUMPING TEST
(Specify one by circling)


Test Rate 8 G.P.M. Duration of test _____ hrs
Drawdown 75 ft ft. Date _____
Static level-depth to water 72 ft ft.
Quality (clear, cloudy, taste, odor) _____
Pump installed by _____

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Clay</u>	<u>0 Feet</u>	<u>84 Ft.</u>
<u>Sand</u>	<u>84</u>	<u>86</u>
<u>Clay</u>	<u>86</u>	<u>96.8</u>
<u>Sand</u>	<u>96.8</u>	<u>99.4</u>
<u>Clay</u>	<u>99.4</u>	<u>213</u>
<u>Sand</u>	<u>213</u>	<u>215</u>
<u>Clay</u>	<u>215</u>	<u>275</u>
<u>fine sand</u>	<u>275</u>	<u>278</u>
<u>Gravel</u>	<u>278</u>	<u>280</u>
<u>water 280 ft</u>		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



S.

(31)

Drilling Firm Plummer & McMillan
Address Galena, O.

Date Sept 20 - 72
Signed Charles Plummer

*If additional space is needed to complete well log, use next consecutive numbered form.