WEL LOG AND DRILLING RE RT

ORIGINAL

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

445908

County Geauga Township Hambden Section of Township

Owner John Washington Address 9050 Williams Rd

Location of property 1/2 mi N of 166

CONSTRUCTION DETAILS

Casing diameter 5 5/8 Length of casing 71

Type of screen Length of screen

Type of pump Red Jacket sub

Capacity of pump 1/3 H

Depth of pump setting 75

Date of completion 11/10/72

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 10 G.P.M. Duration of test 1 hrs

Drawdown 15 ft. Date 11/10/72

Static level-depth to water 30 ft.

Quality (clear, cloudy, taste, odor) clear

Pump installed by Hendershot

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
yellow clay	0 Feet	25 Ft.
hard pan	25	61
Blue Mud	61	71
limestone	71	90

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm

Address RD 1 Box 60 Chardon 0

Date 11/10/72

Signed W. C. Hendershot

26

*If additional space is needed to complete well log, use next consecutive numbered form.