

ORIGINAL

Columbus, Ohio 43215

County TRUMBULL Township VIENNA Section of Township _____
 Owner ANNETTE CANDELLA Address 426 SCOVALLE NORTH RD
 Location of property House on West Side of Scoville North Rd
off Route 82 to the South,
 CONSTRUCTION DETAILS _____
 BAILING OR PUMPING TEST _____
 (Specify one by circling)

CONSTRUCTION DETAILS

Casing diameter 5" ID Length of casing 28'
Type of screen NONE Length of screen —
Type of pump ELECT
Capacity of pump 9 GAL MIN-AT 100'
Depth of pump setting 80
Date of completion _____

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 25 G.P.M. Duration of test 2 hrs
Drawdown 45 ft. Date Aug 1, 74
Static level-depth to water 12 ft.
Quality (clear, cloudy, taste, odor) Clear
Pump installed by B. A. Minotti

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Clay, Yellow	0 Feet	17 Ft.
SAND & GRAVEL	17	26
GRAY SANDSTONE	26	65
Shale Rock	65	90
Water		
A+		
28-43		
60-75		
80		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

St. Route 92

W

St. Rt. 11

Egoalle

Horton - North 2d

S.

E.

Drilling Firm WAKEHAM DRILLING
Address RD 2 NEWTON FALLS, O.

Date Aug 2 1961
Signed J. D. Winsett

*If additional space is needed to complete well log, use next consecutive numbered form.