

64

454102

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

County Licking Township Harrison Section of Township UNK
Owner Bardka Foot Address Pataskala 0
Location of property 1/2 mile E of SR 310 - Left Side

BAILING OR PUMPING TEST
(Specify one by circling)

Casing diameter 5 Length of casing 232
Type of screen — Length of screen —
Type of pump 5 sub
Capacity of pump 10 GPM
Depth of pump setting 160
Date of completion Aug 10 - ~~78~~ 77

Test Rate 10 G.P.M. Duration of test 2 hrs.
Drawdown 10 ft. Date Aug 10-77
Static level-depth to water 90 ft.
Quality (clear, cloudy, taste, odor) Clear
Pump installed by _____

SKETCH SHOWING LOCATION

From	To
0 Feet	232 Ft.

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

Clay
Rock

232 268

N

148

W.

E

SR 16

SR 310
S.

Drilling Firm Parashala Well Drilling Date Aug 10-85

Address 2560 Hayes Rd

Signed W. W. Watson

LOCATED

*If additional space is needed to complete well log, use next consecutive numbered form.