WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

454824

County Stark Township ~~City of Canton~~ Plain Section of Township

Owner Tom Oleyar Address 5328 Shuller N.E.

Location of property 5328 Shuller St N.E. Canton

CONSTRUCTION DETAILS

Casing diameter 5" Length of casing 31'8"

Type of screen — Length of screen

Type of pump Sub.

Capacity of pump 6 GPM

Depth of pump setting 37

Date of completion 7/15/74

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 15 G.P.M. Duration of test 1 hrs.

Drawdown 5 ft. Date 7/15/74

Static level-depth to water 20 ft.

Quality (clear, cloudy, taste, odor) Clear

Pump installed by Johnston Drilling

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
sand	0 Feet	25 Ft.
Clay	25	28
shale	28	38
sandstone	38	43

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm Johnston Drilling Date 7/15/74

Address 4400 Shepler Ave SW Canton O Signed D E Johnston

*If additional space is needed to complete well log, use next consecutive numbered form.