

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

454830

County Stark Township Plain Section of Township 9

Owner Robert Potts Address 1719 Steiner Ave. N.W.
N. Canton

Location of property _____

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST (Specify one by circling)

Casing diameter <u>5 in.</u> Length of casing <u>92 ft.</u>	Test Rate <u>15</u> G.P.M. Duration of test <u>1</u> hrs.
Type of screen <u>XX</u> Length of screen _____	Drawdown <u>5</u> ft. Date <u>4-9-75</u>
Type of pump <u>?</u>	Static level-depth to water <u>15</u> ft.
Capacity of pump _____	Quality (clear, cloudy, taste, odor) <u>Clear</u>
Depth of pump setting _____	
Date of completion <u>4-10-75</u>	Pump installed by <u>?</u>

WELL LOG*

SKETCH SHOWING LOCATION

Formations Sandstone, shale, limestone, gravel and clay	From	To
sand & gravel	0 Feet	52 Ft.
clay & sand	52	78
clay	78	85
shale ? clay	85	88
shale	88	96
sandstone	96	100

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

Applegrove

W. 646

STEINER

Murphy

Eaton

S.

5143 N. market

E.