

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

455117

County Richland Township Springfield Section of Township 10
Owner Murrell J. Yarnan Address 1616 N. Rock Rd.
Location of property 3/10 mile No of Walker Lake Rd. on Right

CONSTRUCTION DETAILS

Casing diameter 6 Length of casing 70
Type of screen NONE Length of screen —
Type of pump Submersional
Capacity of pump 20 gal min
Depth of pump setting 80 ft.
Date of completion 5-20-79

BAILING OR PUMPING TEST (Specify one by circling)


Test Rate 20 G.P.M. Duration of test 1 hrs.
Drawdown NONE ft. Date 4-14-79
Static level-depth to water 22 ft.
Quality (clear, cloudy, taste, odor) Clear
Pump installed by H.M. Riker Drilling

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>yellow Clay</u>	<u>0 Feet</u>	<u>20 Ft.</u>
<u>Gray Clay + Sand</u>	<u>20</u>	<u>49</u>
<u>Brown sand</u>	<u>49</u>	<u>54</u>
<u>Soft yellow sand</u>		
<u>Stone</u>	<u>54</u>	<u>70</u>
<u>Red Sandstone</u>	<u>70</u>	<u>83</u>
<u>Blue Clay</u>	<u>83</u>	<u>84</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm H.M. Riker
Address 1094 W. Longview ave.

Date 5-5-79
Signed Roger S. Riker

*If additional space is needed to complete well log, use next consecutive numbered form.