WEI LOG AND DRILLING REI RT

ORIGINAL

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

455118

County Richland Township Spring Field Section of Township 34

Owner Bill Jones Address 2959 Noblet Rd.

Location of property 3 1/2 Mile on Left on Noblet Rd of Lexington Ontario Rd.

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 137

Type of screen None Length of screen None

Type of pump Submersible

Capacity of pump 10 gal min

Depth of pump setting 234

Date of completion 5-25-80

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 10 G.P.M. Duration of test 2 hrs.

Drawdown 20 ft. Date 5-30-80

Static level-depth to water 197 ft.

Quality (clear, cloudy, taste, odor) Clear

Pump installed by H.M. Likes Drilling

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
yellow Clay + Sand	0 Feet	25 Ft.
Gray Clay + Sand	25	125
yellow Sandstone	125	137
yellow Sandstone	137	244

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm H.M. Likes Date 6-5-80

Address 1094 W Longview Ave Signed Roger S. Likes

*If additional space is needed to complete well log, use next consecutive numbered form.

716