

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

361
459458

County Medina Township Hinchley Section of Township _____
Owner Mr & Mrs Wm. R. Raley Address 423 Ridge Rd
Location of property Hinchley Ohio 44233 - Phone 278 4656

TD-143 CONSTRUCTION DETAILS

Casing diameter 5" ID Length of casing 148'-3"
Type of screen NONE Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting 100 ft
Date of completion _____

BAILING OR PUMPING TEST be 5:05 PM
well could (Specify one by circling) my test with Bailor
Test Rate 30 G.P.M. Duration of test 35 hrs.
Drawdown 20 ft. Date Oct 25 '74
Static level-depth to water 17 ft.
Quality (clear, cloudy, taste, odor) Cloudy, but
may clear up on Pump
Pump installed by To be - later date


WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Yellow Clay</u>	<u>0 Feet</u>	<u>3' Ft.</u>
<u>Sandy Yellow Clay</u>	<u>3'</u>	<u>6'</u>
<u>Gray Sandy Shale mixed with</u>		
<u>Gravel 1/2 to 1/4 size</u>	<u>6'</u>	<u>19'</u>
<u>Gray Sandy Shale</u>	<u>19'</u>	<u>46'</u>
<u>With Fine Grained</u>	<u>46'</u>	<u>88'</u>
<u>Gray Soft Mud</u>	<u>88'</u>	<u>104'</u>
<u>With "sand" & shale</u>	<u>104'</u>	<u>130'</u>
<u>Sandy Dark shale</u>	<u>130'</u>	<u>138'</u>
<u>Dark Gray Gravel all colors</u>		
<u>from 25 slot size</u>	<u>up to</u>	<u>1/4"</u>
<u>3/4 is dark full water</u>	<u>138'</u>	<u>143'</u>
<u>Total Depth</u>	<u>143 feet</u>	

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

P.H. Test was 7 Grams Hardness
10.



Date Oct 25-74 - Drillers, Lawrence

Signed Bolte and Paul Baldern

my 38 years

*If additional space is needed to complete well log, use next consecutive numbered form.

44280