WE LOG AND DRILLING RE RT

(83) ORIGINAL

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

461590

County FRANKLIN Township JACKSON Section of Township

Owner MILBURN BROWN Address 1831 DYER RD

Location of property SO. SIDE RD

CONSTRUCTION DETAILS

Casing diameter 4 1/2 OD Length of casing 52-3

Type of screen PERC Length of screen 2FT

Type of pump

Capacity of pump

Depth of pump setting

Date of completion

BAILING OR PUMPING TEST
(Specify one by circling)

BAIL ~~Test~~ Rate 8 G.P.M. Duration of test 2 hrs.

Drawdown NONE ft. Date 11-2-74

Static level-depth to water 37 ft.

Quality (clear, cloudy, taste, odor) CLEAR

Pump installed by

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
CLAY	0 Feet	40 Ft.
SANDY GRAVEL	40	52'3

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm R. G. Ryan Well Drilling Date 11-2-74

Address LOY 39 CGW Signed G. F. Ryan

211

*If additional space is needed to complete well log, use next consecutive numbered form.

12