

WELL LOG AND DRILLING REPORT

#343 Loc. Elev. 830
(CONTINUED 8301) ORIGINAL

LOCATED

State of Ohio
OHIO WATER RESOURCES BOARD
Department of Public Works
553 E. Broad St., Columbus 15, Ohio8/31/59 RT
No. 46516
393 18County Minia Township Bethel Section of Township
or Lot Number
Owner Harold Kerschel Address R#1 New Carlisle O
Location of property 1 1/2 miles no of Rt. 70 on R#201

CONSTRUCTION DETAILS

Casing diameter 5 5/8 Length of casing 62
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting

PUMPING TEST

Boiler TestPumping rate 10 G.P.M. Duration of test 1 hrs.
Drawdown 12 ft. Date Oct 18 - 1958
Developed capacity
Static level of completed well 35 ft.
Pump installed by

WELL LOG

SKETCH SHOWING LOCATION 18

Formations
Sandstone, shale, limestone,
gravel and clay

From

To

0 Feet

3 Ft.

Top soilClay38Clay + gravel835Clay3552Sand + gravel5262Water at62 ft.Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.UL N
Well x
W. RT 70 ERT
201

S

See reverse side for instructions

343