

**ORIGINAL.**

State of Ohio  
DEPARTMENT OF NATURAL RESOURCES  
Division of Water  
65 S. Front St., Rm. 815 Phone (614) 469-2646  
Columbus, Ohio 43215

469561

Owner Eli Miller Address Londonville

Location of property, 2307 Street place on Right

**BAILING OR PUMPING TEST**  
(Specify one by circling)

Test Rate 10 G.P.M. Duration of test 1/2 hrs.

Drawdown 5 ft. Date Nov 8

Static level-depth to water 50 ft.

Quality (clear, cloudy, taste, odor)\_\_\_\_\_

\_\_\_\_\_

Pump installed by owner

SKETCH SHOWING LOCATION

**To**

Locate in reference to numbered  
State Highways, St. Intersections, County roads, etc.

**N.**

St Agstone

0 Feet

20 Ft.

gray shale

20

50

Slag stone

50

30

water in flintstone

28

Sims

66

305

Yellow-A

**S.**

**E.**

Date Nov 8 - 78

Signed 

\*If additional space is needed to complete well log, use next consecutive numbered form.