+75

ORIGINAL

WELL LOG AND DRILLING REPORT

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

469563 P

County WAYNE Township Clinton Section of Township 5

Owner Harold Buches Address Shreve Ohio RD 1

Location of property on co RD 16 1 mile off 3

CONSTRUCTION DETAILS

Casing diameter 5 Length of casing 30

Type of screen - Length of screen -

Type of pump sub

Capacity of pump 10 gal / min

Depth of pump setting 50 ft

Date of completion Aug 13-75

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 1.5 G.P.M. Duration of test ½ hrs.

Drawdown 2 ft. Date Aug 13-75

Static level-depth to water 40 ft.

Quality (clear, cloudy, taste, odor)

Pump installed by Ralph Shorts

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Glas stone	0 Feet	30 Ft.
gray shale	30	50
Glas stone	50	60
water 55		

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm Shorts Drilling Date Aug 20-75

Address RD 2 Londonville Signed Ralph E Short

23

*If additional space is needed to complete well log, use next consecutive numbered form.