

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Geological Survey
Fountain Square
Columbus, Ohio 43224 Phone

Phone (614) 466-5344

OWNER Jim SHIMP ADDRESS _____

LOCATION OF PROPERTY REFUGEE RD.

BAILING OR PUMPING TEST
(specify one by circling)

Casing diameter <u>5"</u>	Length of casing <u>79'68"</u>	Test rate <u>16</u> gpm	Duration of test <u>1</u> hrs
Type of screen _____	Length of screen _____	Drawdown <u>3</u> ft	Date <u>10/8/76</u>
Type of pump <u>RED JACKET</u>		Static level (depth to water) <u>28'</u>	ft
Capacity of pump <u>12 GPM</u>		Quality (clear, <u>cloudy</u> , taste, odor) _____	
Depth of pump setting <u>65'</u>			
Date of completion <u>3/7/77</u>		Pump installed by <u>PICKERINGTON W/D</u>	

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.

BROWN CLAY	0 ft	17	ft
GRAY CLAY & SAND	18	52	
GRAY CLAY	53	60	
BROWN CLAY & SAND	61	67	
BED ROCK - SANDSTONE	68'	79	
GOOD WELL	79'		

A hand-drawn map showing a rectangular area. The top is labeled 'N', the left 'W', and the right 'E'. Inside the rectangle, the text 'REFUGEE TR.' is written with an arrow pointing downwards. On the left side, 'RT #250' is written with an arrow pointing left. On the right side, 'RT 204' is written with an arrow pointing left. At the bottom center, there is a small square labeled 'WELL' with an arrow pointing towards it.

DATE 3-8-77
SIGNED Ronald D. Proke

*If additional space is needed to complete well log, use next consecutive numbered form.

