

WEI LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Geological Survey
Fountain Square
Columbus, Ohio 43224 Phone (614) 466-5344

497511

COUNTY WARREN TOWNSHIP Salem SECTION OF TOWNSHIP
OR LOT NUMBER _____
OWNER HARLAN EAST FORK WATER CO. ADDRESS PT. PLEASANT, OHIO
LOCATION OF PROPERTY MORROW ROAD

CONSTRUCTION DETAILS

Casing diameter 12" Length of casing 67'
Type of screen W.W. Length of screen 12'
Type of pump NOT INSTALLED
Capacity of pump _____
Depth of pump setting _____
Date of completion NOV 1974

BAILING OR PUMPING TEST


(specify one by circling)

Test rate 227 gpm Duration of test 6 hrs
Drawdown 34 ft Date 11-7-74
Static level (depth to water) 28' ft
Quality (clear, cloudy, taste, odor) CLEAR - GOOD
TASTE - NO ORDER
Pump installed by WILL BE INSTALLED
BY DIEHL PUMP

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
<u>OVERLAY</u>	0 ft	<u>22</u> ft
<u>SANDY YELLOW CLAY</u>	<u>22</u>	<u>24</u>
<u>COARSE GRAVEL + ROCKS</u>	<u>24</u>	<u>40</u>
<u>ROCKS W/ TRACE CLAY</u>	<u>40</u>	<u>41</u>
<u>ROCKS W/ BROWN SAND</u>	<u>41</u>	<u>43</u>
<u>COARSE GRAVEL W/ CLAY</u>	<u>43</u>	<u>58</u>
<u>GRAY CLAY</u>	<u>58</u>	<u>62</u>
<u>FINE BROWN SAND W/ CLAY</u>	<u>62</u>	<u>65</u>
<u>LARGE GRAVEL W/ CLAY</u>	<u>65</u>	<u>68</u>
<u>LARGE ROCK + GRAVEL</u>	<u>68</u>	<u>69</u>
<u>BLUE CLAY</u>	<u>69</u>	<u>70</u>
<u>COARSE SAND + GRAVEL</u>	<u>70</u>	<u>79</u>
<u>BED ROCK</u>		

SKETCH SHOWING LOCATION



DRILLING FIRM DIEHL PUMP CO
ADDRESS 550 N. WAYNE AVE
CINCINNATI, OHIO 45215

DATE 1/21/75
SIGNED L & Brewer

*If additional space is needed to complete well log, use next consecutive numbered form.