

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

498580

COUNTY Greene ~~CLARK~~ TOWNSHIP Beth SECTION OF TOWNSHIP _____
OWNER JOHN F. PATIN ADDRESS 694 WILKERSON RD.
LOCATION OF PROPERTY 694 WILKERSON RD.

CONSTRUCTION DETAILS

~~SAILING~~ OR PUMPING TEST
(specify one by circling)

Casing diameter 5 5/8 Length of casing 70' Test rate 10 gpm Duration of test 24 hrs
Type of screen _____ Length of screen _____ Drawdown 15 ft Date 5/20/77
Type of pump _____ Static level (depth to water) 50 ft
Capacity of pump _____ Quality (clear, cloudy, taste, odor) CLEAR
Depth of pump setting _____ Pump installed by W. D. RICHARDSON CORP.
Date of completion _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

TOP SOIL	0 ft	4 ft
YELLOW CLAY GRAVEL	4	30
BLUE CLAY	30	70
ROCK WATER	70	92

W

N

WILKERSON

E

92' 0"
70'

924

S

DRILLING FIRM W. D. Richardson Corp.
ADDRESS 207 BELLSHOCK AVE.

DATE 5/21/77
SIGNED P. D. RICHARDSON

*If additional space is needed to complete well log, use next consecutive numbered form.

143