WEL LOG AND DRILLING REP RT

ORIGINAL

NO CARBON PAPER NECESSARY – SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

498834

COUNTY Summit TOWNSHIP Norton SECTION OF TOWNSHIP

OWNER Frank Smith ADDRESS 4466 Rockcut Rd Norton.

LOCATION OF PROPERTY 4789 Home ave, Norton

CONSTRUCTION DETAILS

Casing diameter 5" Length of casing 144

Type of screen Length of screen

Type of pump

Capacity of pump

Depth of pump setting

Date of completion

BAILING OR PUMPING TEST
(specify one by circling)

Test rate 12 gpm Duration of test 2 hrs

Drawdown 80 ft Date 7-17-80

Static level (depth to water) 65 ft

Quality (clear, cloudy, taste, odor)

Pump installed by

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
Sand + Clay	0 ft	10 ft
Blue Clay + Gravel	10	70
Sand + Gravel	70	90
Blue Clay + Gravel	90	128
Shale Rock	128	160

SKETCH SHOWING LOCATION

Locate in reference to numbered state highways, street intersections, county roads, etc.



DRILLING FIRM Weekley Well Drilling DATE 7-17-8

ADDRESS 26560 Van Dorhoof RD Berk. SIGNED E. Weekley

*If additional space is needed to complete well log, use next consecutive numbered form.

784