

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

498871

COUNTY Lawrence TOWNSHIP Perry SECTION OF TOWNSHIP 29
OWNER Kenneth Hastings ADDRESS Rt 5 Box 434
LOCATION OF PROPERTY South Point - On Delta lane - half way between old + New US 52

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 5 5/8 Length of casing 86'
Type of screen 3/8" Cook Sand screen for 5 5/8" Length of screen 48"
Type of pump sub - 1 hp valley
Capacity of pump 1000 GPM
Depth of pump setting 75'
Date of completion Jan 78

Test rate 16 gpm Duration of test 1 hrs
Drawdown 50 ft Date Nov 77
Static level (depth to water) 45 ft
Quality (clear, cloudy, taste, odor) clear - good taste
no odor
Pump installed by owner

WELL LOG*

SKETCH SHOWING LOCATION


Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

yellow sandy clay	0 ft	18 ft
yellow sand	18	45
yellow sand + small gravel	45	49
yellow fine sand	49	75
gray coarse sand + gravel	75	85
gray clay	85	86
gray sandstone	86	
bedrock		



water at approx 50 ft
+ 75 to 85 ft

DRILLING FIRM Borders Water Well Service
ADDRESS Rt 1 Box 10A Iron-on
Ohio 45638

DATE 6 Feb 78
SIGNED John Borders Jr

*If additional space is needed to complete well log, use next consecutive numbered form.