

WEI LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

499543

COUNTY Champaign TOWNSHIP Urbana SECTION OF TOWNSHIP South
OWNER Leon Wingfield ADDRESS Timberly Trail
LOCATION OF PROPERTY Off of Middle Urbana Rd

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST (specify one by circling)

Casing diameter 6.00 Length of casing 86 ft Test rate 20 gpm Duration of test 1 hrs
Type of screen _____ Length of screen _____ Drawdown 5 ft Date 7-7-79
Type of pump _____ Static level (depth to water) 55 ft
Capacity of pump _____ Quality (clear) (clear, cloudy, taste, odor) _____
Depth of pump setting _____ Pump installed by _____
Date of completion _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Clay	0 ft	35 ft
Gravel & sand	35	75
Clay & sand	75	86
Water at	86	

W

N

E

S

DRILLING FIRM

DATE

ADDRESS

SIGNED

*If additional space is needed to complete well log, use next consecutive numbered form.

30.5