

NO CARBON PAPER
NECESSARY-
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

501830

COUNTY Wayne TOWNSHIP Plains SECTION OF TOWNSHIP Sec 20
OWNER Dennis Wile ADDRESS 587 High St. Ironville O
LOCATION OF PROPERTY 1/2 mile East of Blackberryville 1/4 mi. on 189 T.R.

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 5 " Length of casing 55'

Test rate 14 gpm Duration of test 1 hrs

Type of screen _____ Length of screen _____

Drawdown 5 ft Date 11-5-76

Type of pump _____

Static level (depth to water) 70 ft

Capacity of pump _____

Quality (clear, cloudy, taste, odor) clear

Depth of pump setting _____

Pump installed by _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale, limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Clay
Rock

0 ft

55th

5577

106 ft

W

N

E

S

