

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

505051

COUNTY Summit TOWNSHIP Hudson SECTION OF TOWNSHIP _____
OWNER Ryan Homes, Inc. ADDRESS 542 Graham Rd - C.F.O.
LOCATION OF PROPERTY 1776 Carver Lane - Hudson TWP

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 5" Length of casing 34' Test rate 20 gpm Duration of test 1/2 hrs
Type of screen NONE Length of screen _____ Drawdown 20 ft Date 8-26-76
Type of pump _____ Static level (depth to water) 80 ft
Capacity of pump _____ Quality (clear, cloudy, taste, odor) Clear - no
Depth of pump setting _____ Taste or odor
Date of completion _____ Pump installed by _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

0 ft 34 ft
Clay
Shale + limestone 34 153

TO HUDSON, O. N

Ohio 91

Well @
1776

CARVER

EASTMAN

W

E

Carver

Barlow Rd
S

DRILLING FIRM Herr Fieldman
ADDRESS 600 Chart Rd - C.F.O.

DATE 8-26-76
SIGNED Herr Fieldman

*If additional space is needed to complete well log, use next consecutive numbered form.