

WEI LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

506209

COUNTY Fairfield TOWNSHIP Hocking SECTION OF TOWNSHIP _____
OWNER Thomas F. Walters ADDRESS 4495 Hopewell Church Rd. Lancaster Oh
LOCATION OF PROPERTY _____

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST (specify one by circling)

Casing diameter 5" Length of casing 61
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion Oct 8, 1976
Test rate 10 gpm Duration of test 1 hrs
Drawdown 6.0 ft Date Oct 8, 1976
Static level (depth to water) 40 ft
Quality (clear, cloudy, taste, odor) clear
Pump installed by _____

WELL LOG*

SKETCH SHOWING LOCATION


Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Clay	0 ft	12 ft
Clay - Broken SS	12	45
Stringers		
Gray Shale	45	60
Brown Sandstone	60	66
Shale w/SS stringers	66	80
Sandstone w/line	80	119
clay seams		
70 ft 4" 10 plastic perforated sitting on bottom		
Set pump around 100 ft Pump at out on <u>100 ft</u>		



DRILLING FIRM

ADDRESS

DATE

SIGNED

*If additional space is needed to complete well log, use next consecutive numbered form.

234
LOCATED
234