WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER NECESSARY– SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

506335

COUNTY ~~Jacksonville~~ Mahoning TOWNSHIP ~~Lordstown~~ Jackson SECTION OF TOWNSHIP

OWNER Eugene Vallozzi ADDRESS Richard Ohltown Rd

LOCATION OF PROPERTY 3/4 mile N of 45 on " " "

CONSTRUCTION DETAILS

Casing diameter 5 5/8 Length of casing 26

Type of screen _____ Length of screen _____

Type of pump _____

Capacity of pump _____

Depth of pump setting _____

Date of completion _____

BAILING OR PUMPING TEST
(specify one by circling)

Test rate 20 gpm Duration of test 4 hrs

Drawdown 10 ft Date 6-29-77

Static level (depth to water) 10 ft

Quality (clear, cloudy, taste, odor) _____

Pump installed by _____

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
Clay	0 ft	18 ft
Sand Rock	18	75

SKETCH SHOWING LOCATION

Locate in reference to numbered state highways, street intersections, county roads, etc.



DRILLING FIRM W & W DRILLING CO. 875 WILSON-SHARPSVILLE RD. CORTLAND, OHIO

DATE 8-12-77