

WEL' LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

508277

83 ✓

COUNTY Miami TOWNSHIP Concord SECTION OF TOWNSHIP 8153
OWNER Lester Robbins ADDRESS 8153 Coarfed St. Troy, Ohio
LOCATION OF PROPERTY 2nd house on right on top of Union St.

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 6" O.D. Length of casing 42 ft Test rate 20 gpm Duration of test 3 hrs
Type of screen Jet Length of screen Drawdown 4 ft Date 11/7/77
Type of pump Jet Static level (depth to water) 19 ft ft
Capacity of pump 360 G.P.H. Quality (clear, cloudy, taste, odor) Clear
Depth of pump setting 39 ft
Date of completion 11/7/77 Pump installed by Owner

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Formations: sandstone, shale, limestone, gravel, clay	From	To
Topsoil & clay	0 ft	6 ft
dry gravel	6	25
shale	25	38
gravel (water)	38	42

W

N

Union St.

E

JEEP ST.

WELL

S

RECEIVED

NOV 09 1977

HEALTH DEPARTMENT
TROY, OHIO

DRILLING FIRM

DATE

ADDRESS

SIGNED

Heckman Well Drilling 11/7/77
920 E. Evans Rd.
Troy City, Ohio 45371
George A. Thompson
(driller)

*If additional space is needed to complete well log, use next consecutive numbered form.