

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

514971

COUNTY Wahne TOWNSHIP Wahne SECTION OF TOWNSHIP _____
OWNER James Rice ADDRESS Box 472 Waverly
LOCATION OF PROPERTY On 11 Rd Waverly

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 5 3/4 Length of casing 52
 Type of screen _____ Length of screen _____
 Type of pump _____
 Capacity of pump _____
 Depth of pump setting _____
 Date of completion _____

Test rate 30 gpm Duration of test 2 hrs
 Drawdown 7 ft Date 10-11-78
 Static level (depth to water) 45 ft
 Quality (clear, cloudy, taste, odor) Clear
 Pump installed by _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

0 ft

ft

16

48

48

80

CLAY

SAND GRAV

limestone

WATER @ 48

Locate in reference to numbered
state highways, street intersections, county roads, etc.

N

W

E

O

O NC 112 RD

County Rd 240

843
48
795

S

DRILLING FIRM H. Love
ADDRESS W. R. 20501/14

DATE Herschel Low 8 10-22-78

SIGNED _____