

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY-
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

515767

COUNTY MONT. TOWNSHIP BUTLER SECTION OF TOWNSHIP _____
OWNER JOHN DINEEN ADDRESS GRANITE DRIVE
LOCATION OF PROPERTY 7320 FREDERICK RD

CONSTRUCTION DETAILS	BAILING OR PUMPING TEST (specify one by circling)
Casing diameter <u>6"</u> Length of casing <u>55'</u>	Test rate <u>6</u> gpm Duration of test <u>3</u> hrs
Type of screen _____ Length of screen _____	Drawdown <u>32</u> ft Date <u>SEPT 16 83</u>
Type of pump <u>SUB</u>	Static level (depth to water) <u>23</u> ft
Capacity of pump <u>8 gpm</u>	Quality (clear, cloudy, taste, odor) <u>clear</u>
Depth of pump setting <u>100'</u>	Pump installed by <u>HOMER HALL</u>
Date of completion _____	

WELL LOG*			SKETCH SHOWING LOCATION
Formations: sandstone, shale, limestone, gravel, clay	From	To	Locate in reference to numbered state highways, street intersections, county roads, etc.
<u>Clay</u>	0 ft	54 ft	N W E <u>YITTLE YORK RD</u> <u>FREDRICK RD.</u> S
<u>SHALE</u>	54	55	
<u>Limestone</u>	55	78	
<u>SHALE</u>	78	115	
<u>water at 55'</u>			
<u>1299</u>			

DRILLING FIRM HALL'S WELL DRILLING DATE OCT 14 83
ADDRESS 3512 CHARLES DR SIGNED Homer Hall

*If additional space is needed to complete well log, use next consecutive numbered form.