

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

517090

COUNTY Portage TOWNSHIP Ravenna SECTION OF TOWNSHIP 12
OWNER A. Keen ADDRESS 2458 Brady Lake Rd Ravenna
LOCATION OF PROPERTY 2454 Brady Lake Rd Ravenna OH 44266

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 5" Length of casing 43 1/2'
Type of screen Drop Length of screen 6'
Type of pump jet
Capacity of pump 4 GPM
Depth of pump setting 40'
Date of completion —

Test rate 4 gpm Duration of test 2 hrs
Drawdown 6 ft Date 12/16/77
Static level (depth to water) 30' ft
Quality (clear, cloudy, taste, odor) clear
Pump installed by Anderson

WELL LOG*

SKETCH SHOWING LOCATION


Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

<u>Br Sand</u>	<u>0 ft</u>	<u>21 ft</u>
<u>Dirty Gray Sand</u>	<u>21</u>	<u>31</u>
<u>Gray Clay</u>	<u>31</u>	<u>42</u>
<u>Fine Gray Sand</u>	<u>42</u>	<u>50'</u>



DRILLING FIRM Anderson DATE 12/16/77
ADDRESS 2454 Brady Lake Rd Ravenna OH 44266 SIGNED Jeff Fesch Pres

*If additional space is needed to complete well log, use next consecutive numbered form.

103