

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

521666

COUNTY Lorain TOWNSHIP Amherst SECTION OF TOWNSHIP _____
OWNER James Mann ADDRESS 45170 St Rt 113 South Amherst Ohio
LOCATION OF PROPERTY _____

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter <u>6 5/8</u> Length of casing <u>25</u>	Test rate <u>50</u> gpm Duration of test <u>1</u> hrs
Type of screen _____ Length of screen _____	Drawdown <u>30</u> ft Date <u>11-9-77</u>
Type of pump _____	Static level (depth to water) <u>3</u> ft
Capacity of pump _____	Quality (clear, cloudy, taste, odor) <u>cloudy</u>
Depth of pump setting _____	Pump installed by _____
Date of completion _____	

WELL LOG*

SKETCH SHOWING LOCATION


Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

<u>sand and gravel</u>	0 ft	10 ft
<u>sandstone</u>	10	15
<u>red shale</u>	15	21
<u>sandstone</u>	21	49



DRILLING FIRM Agman Drilling DATE 11-9-77
ADDRESS Thompson Reclamation Vermilion Ohio SIGNED James Mann

*If additional space is needed to complete well log, use next consecutive numbered form.