

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

523003

COUNTY ROSS TOWNSHIP Union SECTION OF TOWNSHIP NORTH EAST
OWNER MIKE Mc ROBERTS ADDRESS Rt 1 Chillicothe Ohio. Stone
LOCATION OF PROPERTY East side of Stone Rd. 3/4 mile from East Sect. of St. Rt. 207

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 6" Length of casing 69 1/2 ft Test rate 20 gpm Duration of test 1 hrs
Type of screen none Length of screen _____ Drawdown 10 ft Date 12-7-77
Type of pump _____ Static level (depth to water) 52 ft ft
Capacity of pump _____ Quality (clear, cloudy, taste, odor) cloudy
Depth of pump setting _____ Pump installed by Owner
Date of completion _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Top Soil	0 ft	1 ft
CLAY	1	6
SAND	6	9
CLAY + GRAVEL	9	40
SAND + GRAVEL	40	43
Blue clay + GRAVEL	43	50
Blue clay	50	63
SAND + GRAVEL	63	67
Water at	63 ft.	

W

E

S

Chillicothe

DRILLING FIRM William Well Drilling
ADDRESS Rt 2 Chillicothe Ohio.

DATE 12-7-77
SIGNED Tommie William

120

*If additional space is needed to complete well log, use next consecutive numbered form.