

WELL LOG AND DRILLING REPORT

ORIGINAL

I 42 ✓

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

523840

COUNTY Clark TOWNSHIP Moorefield SECTION OF TOWNSHIP 16
OWNER Eugene Dicks ADDRESS 3289 Willow Rd.
LOCATION OF PROPERTY Same

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 6" Length of casing 75
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting 60
Date of completion _____
Test rate 1500 gpm 4 Duration of test _____ hrs
Drawdown _____ ft Date _____
Static level (depth to water) 47 ft
Quality clear (cloudy, taste, odor) _____
Pump installed by _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

yellow clay	0 ft	6 ft
yellow gravel	6	35-
yellow sand	35-	41
yellow gravel	41	53-
yellow sand water	53-	64
Blue gravel water	64	75-

gravel Pack 4'

N
W Willow Rd **E**
O. well
28 mi. W of Moorefield
S

T. J. FYFFE

DRILLING FIRM Well Drilling
Phone 399-1020
ADDRESS 543 E. County Line Rd.
SPRINGFIELD, OHIO

DATE Oct 11 1978
SIGNED T. J. Fyffe

*If additional space is needed to complete well log, use next consecutive numbered form.