

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

526922

COUNTY Muskingum TOWNSHIP Hickings SECTION OF TOWNSHIP N-W
OWNER Clinton Wheeler ADDRESS O'Bannon Rd, Washport, OH
LOCATION OF PROPERTY O'Bannon Rd. WASHPORT, OH

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST (specify one by circling)

Casing diameter <u>5 1/2"</u> Length of casing <u>74'</u>	Test rate <u>20</u> gpm Duration of test <u>1</u> hrs
Type of screen <u>—</u> Length of screen <u>—</u>	Drawdown <u>NONE</u> ft Date <u>5/29/79</u>
Type of pump <u>Submersible</u>	Static level (depth to water) <u>50'</u> ft
Capacity of pump <u>5 gpm</u>	Quality (clear, cloudy, taste, odor) <u>clear</u>
Depth of pump setting <u>60'</u>	Pump installed by <u>RANQUEL D & S</u>
Date of completion <u>5/30/79</u>	

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To


Locate in reference to numbered
state highways, street intersections, county roads, etc.

Sandy shale	0 ft	20	ft
Gray shale	20	74	
Sand stone	74	90	

Water at 85'

Rill up to 50'

T.D. 90'



DRILLING FIRM

ADDRESS

DATE

SIGNED

RANQUEL D & S
FAZCYSBURG, OH

5/31/79

Dean RANQUEL

*If additional space is needed to complete well log, use next consecutive numbered form.

(8)