

WELL LOG AND DRILLING REPORT

15
Ber 52924
528127

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

COUNTY Jefferson TOWNSHIP Springfield SECTION OF TOWNSHIP 11
OWNER Baptist Church ADDRESS Bergholz Rd #1 Oh.
LOCATION OF PROPERTY 1/2 mile of Bergholz on St rd 524

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST (Specify one by circling)

Casing diameter 6" Length of casing 40'
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____
Test rate 5 gpm Duration of test _____ hrs
Drawdown 10 ft Date Sept 13-79
Static level (depth to water) 40 ft
Quality clear, cloudy, taste, odor) _____
Pump installed by Kohler

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Fill dirt

0 ft

10 ft

CLAY & SAND

10

20

SHALE

20

30

COAL

30

22

CLAY

32

36

GRAY SANDY SHALE

36

50

DARK SHALE

50

60

Water at 50'

Locate in reference to numbered
state highways, street intersections, county roads, etc.

W

N

E

S

DRILLING FIRM Kohler Drilling
ADDRESS 3106 Aster Rd SE Seid, Oh

DATE 2-27-80
SIGNED Glen Kohler

*If additional space is needed to complete well log, use next consecutive numbered form.

14