

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

528639

COUNTY PREBLE TOWNSHIP JEFFERSON SECTION OF TOWNSHIP 31
OWNER ROBERT A. HILL ADDRESS 7000 NATIONAL RD. E. RICHMOND TOWNSHIP
LOCATION OF PROPERTY 1/2 MI E. OHIO BORDER ON RT #40 EAST

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 5 5/8 Length of casing 150'
Type of screen NONE Length of screen —
Type of pump SUBMERGIBLE
Capacity of pump 1/2 H.P.
Depth of pump setting 136'
Date of completion 3-10-81

Test rate 8 gpm Duration of test 24 hrs
Drawdown 2 ft Date 3-8-81
Static level (depth to water) 120' ft
Quality (clear, cloudy, taste, odor) CLEAR
Pump installed by PROTANI PUMP SERV

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Soil

0 ft

2 ft

Clay

2

70

Dry Gravel

70

82'

Clay

82

124

Water Bearing Gravel

124

150'

Clay

150

