

County Permit No. _____

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBINGState of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

529204

COUNTY Fairfield TOWNSHIP Liberty SECTION OF TOWNSHIP 23
 OWNER William Crutcher ADDRESS 8935 Basic Rd. N.W. - Baltimore, D.
 LOCATION OF PROPERTY 1/2 mile north of Baltimore corporation line - 200 ft. south of Geisy Rd.

CONSTRUCTION DETAILS**BAILING OR PUMPING TEST**

(specify one by circling)

Casing diameter 5" Length of casing 124 ft.
 Type of screen prefab Length of screen 60"
 Type of pump SUBMERSIBLE
 Capacity of pump 10 gal/min
 Depth of pump setting _____
 Date of completion 3-15-79

Test rate _____ gpm Duration of test _____ hrs
 Drawdown _____ ft Date _____
 Static level (depth to water) _____ ft
 Quality (clear, cloudy, taste, odor) _____
 Pump installed by B-B DRILLING INC

WELL LOG***SKETCH SHOWING LOCATION**Formations: sandstone, shale,
limestone, gravel, clay


From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

top soil	0 ft	5 ft
yellow clay	5 ft.	13 ft.
clay	13 ft.	25 ft.
clay + gravel	25 ft.	55 ft.
sand + gravel	55 ft.	58 ft.
sand	58 ft.	65 ft.
clay + gravel	65 ft.	85 ft.
sand + gravel	85 ft.	87 ft.
clay	87 ft.	95 ft.
sand	95 ft.	102 ft.
clay	102 ft.	109 ft.
sand + gravel	109 ft.	124 ft.

W



S

DRILLING FIRM

B-B DRILLING, Inc

ADDRESS

234 Yencer St. BALTIMORE
OHIO

DATE

3-27-79

SIGNED

[Signature]

*If additional space is needed to complete well log, use next consecutive numbered form.

