

County Permit No. _____

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBINGState of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

531359

COUNTY Huron TOWNSHIP Townsend SECTION OF TOWNSHIP _____
OWNER BOB RIGGLEMAN ADDRESS RT 18 E OF NORWALK
LOCATION OF PROPERTY RT #18 1/4 mile E. OF US RT 601**CONSTRUCTION DETAILS****BAILING OR PUMPING TEST**
(specify one by circling)Casing diameter 6" OD Length of casing 18' Test rate 8 gpm Duration of test 1 hrs
Type of screen _____ Length of screen _____ Drawdown 10 ft Date 11-10-80
Type of pump _____ Static level (depth to water) 12' ft
Capacity of pump _____ Quality (clear, cloudy, taste, odor) CLEAR, NO ODOR
Depth of pump setting 70' Pump installed by _____
Date of completion _____**WELL LOG*****SKETCH SHOWING LOCATION**Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.CLAY

0 ft

12 ft

SANDSTONE

12

40

SHALE

40

45

SANDSTONE

45

65

SHALE

65

75

WATER @ 25'AND MOST AT58'

W

N

US RT #18

S

E

DRILLING FIRM SOUDERS-COLMAN
ADDRESS PO 1 Milan OhioDATE 11-10-80
SIGNED Charles R. Souders

*If additional space is needed to complete well log, use next consecutive numbered form.

12