

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

531362

COUNTY Hyron TOWNSHIP New Harrison SECTION OF TOWNSHIP _____

OWNER CLAUDE BAUER ADDRESS WALNUT RD

LOCATION OF PROPERTY WALNUT RD 1/2 MILE S. OF TOWN LG #12

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST
(Specify one by circling)

(specify one by circling)

Casing diameter <u>6" OD</u>	Length of casing <u>37'</u>	Test rate <u>7</u> gpm	Duration of test <u>40</u> hrs
Type of screen <u> </u>	Length of screen <u> </u>	Drawdown <u>12'</u> ft	Date <u>4-3-81</u>
Type of pump <u> </u>		Static level (depth to water) <u>12'</u> ft	
Capacity of pump <u> </u>		Quality (clear, cloudy, taste, odor) <u>Cloudy</u>	
Depth of pump setting <u> </u>			
Date of completion <u> </u>		Pump installed by <u> </u>	

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

0 ft

12 ft

CLAY

CLAYTILL

SANDLER RAVEL

water T

347

Locate in reference to numbered
state highways, street intersections, county roads, etc.

N

W

F

S

DRILLING FIRM SONDERG-CLAHAN

ADDRESS RD #7 Collins. O/H/O

DATE 4-6-81

SIGNED Charley R. Gordon