

1979  
County Permit No.  
214

# WELL LOG AND DRILLING REPORT

ORIGINAL

10d.5

NO CARBON PAPER  
NECESSARY -  
SELF-TRANSCRIBING

State of Ohio  
DEPARTMENT OF NATURAL RESOURCES  
Division of Water  
Fountain Square  
Columbus, Ohio 43224

532351

COUNTY Miami TOWNSHIP Concord SECTION OF TOWNSHIP 34

OWNER Jennie Reed ADDRESS Tow-path Rd. Troy

LOCATION OF PROPERTY Tow-path Rd. Troy - South of Troy on 25-A. Left on Dye mill Rd. - Right on Tow-path - Trailer on Right

## CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 35'  
Type of screen none Length of screen \_\_\_\_\_  
Type of pump Submersible  
Capacity of pump \_\_\_\_\_  
Depth of pump setting 30'  
Date of completion 10-26-79

## BAILING OR PUMPING TEST

(specify one by circling)

Test rate 10+ gpm Duration of test 1/2 hrs  
Drawdown 0 ft Date 10-10-79  
Static level (depth to water) 9 ft  
Quality (clear, cloudy, taste, odor) Clear  
NO odor  
Pump installed by Henry L. Gregory

## WELL LOG\*

Formations: sandstone, shale,  
limestone, gravel, clay

From

To

0 ft 2 ft

Top Soil

clay

2

5

Sand + Rock

5

22

clay

22

27

gravel + wtr.

27

35

wtr at 28'


RECEIVED

OCT 30 1979

HEALTH DEPARTMENT  
TROY, OHIO

## SKETCH SHOWING LOCATION

Locate in reference to numbered  
state highways, street intersections, county roads, etc.



DRILLING FIRM Gregory & Sons  
ADDRESS 1430 Sanders Rd  
Troy, Ohio 45373

DATE 10-29-79  
SIGNED Henry L. Gregory

\*If additional space is needed to complete well log, use next consecutive numbered form.

174