

County Permit No.

239

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

532353

COUNTY Miami TOWNSHIP Bethel SECTION OF TOWNSHIP _____

OWNER Kenneth Lowery ADDRESS Tipp City

LOCATION OF PROPERTY 7195 Agenbroad Rd. Tipp City - East of Tipp City on 571
Right on 571 left on Agenbroad - 2nd house on left

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 16" Length of casing 25' Test rate 8 gpm Duration of test 1/2 hrs
Type of screen none Length of screen _____ Drawdown 22 ft Date 11-12-79
Type of pump Submersible Static level (depth to water) 8 ft
Capacity of pump 1 GPM Quality (clear, cloudy, taste, odor) Clear
Depth of pump setting 40' no odor
Date of completion 11-19-79 Pump installed by Henry L. Gregory

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Top Soil	0 ft	1 ft
Clay	1	14
limestone	14	47
Red Rock + wtr	47	51
WTR AT 47		

571

W

E

Studebaker Rd

Agenbroad Rd

LOCATED

140

S

RECEIVED

NOV 20 1979

HEALTH DEPARTMENT
TROY, OHIODRILLING FIRM Gregory + sonsDATE 11-20-79ADDRESS 1430 Sanders RdSIGNED Henry L. Gregory

Troy, Ohio

*If additional space is needed to complete well log, use next consecutive numbered form.