

WELL LOG AND DRILLING REPORT

W-26047

NO CARBON PAPER
NECESSARY-
SELF-TRANSCRIBING

DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

532533

COUNTY Summit TOWNSHIP Hudson SECTION OF TOWNSHIP _____

OWNER Ron Rice ADDRESS P.O. Box 1393 Nunda, Oh.

LOCATION OF PROPERTY 2256 Edgewood

CONSTRUCTION DETAILS

Casing diameter 5" Length of casing 37'
Type of screen 4" Brass Length of screen 7'.040
Type of pump Sub
Capacity of pump 10 gpm
Depth of pump setting 27'
Date of completion 11/27/79

BAILING OR PUMPING TEST

(specify one by circling)

Test rate 6+ gpm Duration of test 1 hrs
Drawdown 15 ft Date 11/26/79
Static level (depth to water) Flowing 10' over grade
Quality (clear, cloudy, taste, odor) clearing
Pump installed by Colewell

WELL LOG*

Formations: sandstone, shale,
limestone, gravel, clay


From

To

Clay	0 ft	27 ft
Sand & gravel	27 ft	37 ft
grey clay	37 ft	38 ft

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



DRILLING FIRM Colewell Drilling
ADDRESS P.O. Box 175 Peninsula, Ok.

DATE 11/26/79
SIGNED Jeffrey Pipes