

87-56

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

533118

COUNTY OTTAWA TOWNSHIP DANBURY SECTION OF TOWNSHIP PARCEL- 11 SEC. 2
OWNER VINCENT M. GRESH ADDRESS 314-E-MAIN-ST. MARBLEHEAD, OHIO
LOCATION OF PROPERTY 3933-ENGLEBECK ROAD 43440

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 13 1/2'
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion 7-28-87

BAILING OR PUMPING TEST

(specify one by circling)

Test rate 20 gpm Duration of test 24 hrs
Drawdown _____ ft Date _____
Static level (depth to water) 9 1/2' ft
Quality (clear, cloudy, taste, odor) CLEAR
Pump installed by OWNER

WELL LOG*

Formations: sandstone, shale,
limestone, gravel, clay

From

To

CLAY 0 ft 3 ft
LIMESTONE 3' 50'

WATER AT 24'

13 1/2' - 6" GALVANIZED
CASING WITH
FLARED-ADAPTOR
ON END
CEMENTED-IN

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.

ROUTE 163

N

ENGLEBECK ROAD

W

⊗ WELL

E

DRIVE WAY

S

DRILLING FIRM

MIKE J. GRESH

DATE

7-28-87

ADDRESS

9415-E. BAY SHORE ROAD
MARBLEHEAD, OHIO 43440

SIGNED

Mike J. Gresh