

County Permit No. _____

WELL LOG AND DRILLING REPORT

15 ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBINGState of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

536743

COUNTY Wayne TOWNSHIP Baughman SECTION OF TOWNSHIP 3
 OWNER Norma Stevic ADDRESS 15493 Fulton Rd.
 LOCATION OF PROPERTY Same

CONSTRUCTION DETAILS**BAILING OR PUMPING TEST**

(specify one by circling)

Casing diameter 6" Length of casing 87'
 Type of screen — Length of screen —
 Type of pump 5 H.P. Sub.
 Capacity of pump 10 G.P.M.
 Depth of pump setting 100'
 Date of completion 4-11-80

Test rate 20 gpm Duration of test 1 hrs
 Drawdown 12' ft Date 4-11-80
 Static level (depth to water) 60 ft
 Quality (clear, cloudy, taste, odor) clear
 Pump installed by —

WELL LOG***SKETCH SHOWING LOCATION**Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Clay	0 ft	22 ft
Mid Sandy Stony - Dist	22	53
Blue Clay	53	74
Soft Shale	74	85
Hard "	85	117

N

Fulton Rd

W ← to Marshallville well 1 1/2 mi

E

Barry Rd.

100'

S

DRILLING FIRM

Stan Kera

DATE

4-18-80

ADDRESS

Marshallville, OH

SIGNED

James B. Slawkey

*If additional space is needed to complete well log, use next consecutive numbered form.