

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

DEPARTMENT OF NATURAL RESOURCES

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

539717

COUNTY Trumbull ~~Lawrence~~ TOWNSHIP LIBERTY SECTION OF TOWNSHIP _____

OWNER JAMES LILLY ADDRESS 1444 SMITHSTONIAN, WYOMING, OHIO
 LOCATION OF PROPERTY ONE MILE E. OF BELMONT AVE ON RT. 304, 0.77 OF SUMMIT AVE
ON SMITHSTONIAN (1444)

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 35'

Type of screen _____ Length of screen _____

Type of pump FRANKLIN submersible

Capacity of pump 13 GPM

Depth of pump setting 73'

Date of completion 9-2-24

BAILING OR PUMPING TEST

(specify one by circling)

Test rate 10 gpm Duration of test 2 hrs

Drawdown 70 ft Date 9-2-24

Static level (depth to water) 30' ft

Quality (clear, cloudy, taste, odor) clear

Pump installed by E. Eppinger

WELL LOG*

Formations: sandstone, shale,
limestone, gravel, clay

From

To

overburden, clay, gravel	0 ft	15	ft
--------------------------	------	----	----

SHALE	15	40
-------	----	----

BR. SANDSTONE	40	44	H ₂ O
---------------	----	----	------------------

SHALE	44	80 H ₂ O
-------	----	---------------------

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.

N

W

E

S

DRILLING FIRM

ADDRESS Box 363 New Bedford, Pa. 16140

DATE _____

SIGNED E. R. Eppinger