

ORIGINAL

539734

COUNTY TEMBALL TOWNSHIP LIBERTY SECTION OF TOWNSHIP _____
OWNER JAMES LILLY ADDRESS 1144 SMITHSTONIA RD
LOCATION OF PROPERTY 1/2 mile before intersection of 304 & Belmont on 304

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 6 5/8 Length of casing 33'
 Type of screen _____ Length of screen _____
 Type of pump Submersible
 Capacity of pump 100 gpm.
 Depth of pump setting 75'
 Date of completion 8/30/24

Test rate 10 gpm Duration of test 2 hrs
 Drawdown 70 ft Date 8/26/24
 Static level (depth to water) 30' ft
 Quality (clear, cloudy, taste, odor) clear
 Pump installed by E.R. Eppinger

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

SAND, CLAY, GRAVEL

0 ft

15 ft

GRAY SHALE

15

40

BROWN SANDSTONE

40

44

GRAY SHALE

44

80

Locate in reference to numbered
state highways, street intersections, county roads, etc.

N

W

E

S

Belmont

well

STATION 125

At 304

DRILLING FIRM Eppinger Well Drilling DATE 9/27/24
ADDRESS Box 365 New Bedford, Pa. 16060 SIGNED E. J. Eppinger

*If additional space is needed to complete well log, use next consecutive numbered form.