

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

543061

COUNTY KNOX TOWNSHIP MORRIS SECTION OF TOWNSHIP -
OWNER GREG COFFING-CONTR. (AL MCQUIGG-OWNER) ADDRESS BOX 1, DUFF ST. CAMBRIER, OH.
LOCATION OF PROPERTY W/5 T-279(DIVELBISS RD); 1/4 mi. NORTH OF T-276(CROOKED ST)

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST
(specify one by circling)Casing diameter 5 3/16 I.D. Length of casing 30'Test rate 12 gpm Duration of test 1 hrsType of screen - Length of screen -Drawdown 20 ft Date 4-18-79Type of pump RECOMMEND - 1/2 H.P. - A - MYERSStatic level (depth to water) 53 ftCapacity of pump RECOMMEND - 11 G.P.M.Quality (clear, cloudy, taste, odor) CLEARDepth of pump setting RECOMMEND - 120'Date of completion -Pump installed by TO BE BY CLARY WELL DRILL.

WELL LOG*

SKETCH SHOWING LOCATION


Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

FILL DIRT	0 ft	2 ft
YELLOW CLAY & SANDSTONE ^{BROKEN}	2	9
YELLOW SANDY SHALE	9	28
YELLOW SANDSTONE & SHALE ^{TAN}	28	87
BLUE SANDSTONE	87	103
YELLOW SANDSTONE	103	123
BLUE SANDSTONE	123	128
YELLOW SANDSTONE	128	130
BLUE SANDSTONE	130	135



WATER AT 40 THRU 135

NOTE: ABOVE SANDSTONES WERE
ALL STREAKED WITH THIN
SLIVERS OF SHALE.

DRILLING FIRM

CLARY WELL DRILLING CO.

DATE

4-18-79

ADDRESS

FREDERICKTOWN, OH.
43019

SIGNED

James E. Clary