

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

544474

COUNTY Township TOWNSHIP mespo SECTION OF TOWNSHIP _____
OWNER MURPHY CARVER ADDRESS 8360 Rt 534
LOCATION OF PROPERTY 1/4 mile south of Rt 87 on EAST side of Rt 534

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 5 5/8 Length of casing 158' Test rate 2-3 gpm Duration of test 4 hrs
Type of screen _____ Length of screen _____ Drawdown 100% ft Date 10-27-81
Type of pump _____ Static level (depth to water) flowing ft
Capacity of pump _____ Quality (clear, cloudy, taste, odor) clear
Depth of pump setting _____ Pump installed by [Signature]
Date of completion _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Top Soil	0 ft	2' ft
Brown Clay	2'	15'
Grey Clay	15'	60'
SAND + GRAVEL	60'	72'
Blue Clay	72'	96'
Blue Sandy Clay + Gravel	96'	136'
SAND	136'	144'
SAND & GRAVEL	144'	158'

W

N

Rt 87

E

Rt 534

S