

1979
County Permit No.
93

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

545798

14f

COUNTY Madison TOWNSHIP Concord SECTION OF TOWNSHIP 12
OWNER Fred Cook ADDRESS Tipp City
LOCATION OF PROPERTY Rt. drive S. of 2790 Washington Rd. W. S. Troy, O

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(Specify one by circling)

Casing diameter 5 5/8 Length of casing 52' Test rate 10 gpm Duration of test 1 hrs
Type of screen _____ Length of screen _____ Drawdown 2 ft Date 5-21-79
Type of pump _____ Static level (depth to water) 5 ft
Capacity of pump _____ Quality (clear, cloudy, taste, odor) clear
Depth of pump setting _____ Pump installed by _____
Date of completion _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Clay

0 ft

5 ft

Dry Gravel

5

10

Clay

10

37

Water Sand

37

49

" Gravel

49

52

W

N

E

S

RECEIVED

MAY 22 1979

HEALTH DEPARTMENT
TROY, OHIO

DRILLING FIRM Stoltzwell Drilling
ADDRESS Troy, O

DATE 5-21-79
SIGNED [Signature]

*If additional space is needed to complete well log, use next consecutive numbered form.