

County Permit No.

WEI LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

545810

COUNTY Crawford TOWNSHIP Holmes SECTION OF TOWNSHIP _____
OWNER Michael Rankins ADDRESS Bucyrus, O.
LOCATION OF PROPERTY on Lemert Rd., 1 Mile W. of (St. Rt. 100)

CONSTRUCTION DETAILS LemertBAILING OR PUMPING TEST
(specify one by circling)

Casing diameter 5 Length of casing 42-8 Test rate 15 gpm Duration of test _____ hrs
Type of screen _____ Length of screen _____ Drawdown 20 ft Date 9-13-79
Type of pump _____ Static level (depth to water) 15 ft
Capacity of pump _____ Quality (clear, cloudy, taste, odor) clear
Depth of pump setting _____ Pump installed by _____
Date of completion _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Clay, yellow
" Blue
Shale
Gravel
Lime Stone

0 ft

12 ft

12

19

19


31

31

35

35

70

Water at 65Locate in reference to numbered
state highways, street intersections, county roads, etc.

DRILLING FIRM

Field

DATE

Sept. 14, 1979

ADDRESS

SIGNED

Raymond Field

*If additional space is needed to complete well log, use next consecutive numbered form.

93