

County Permit No.
D197 C156

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

549103

COUNTY Medina TOWNSHIP Sharon SECTION OF TOWNSHIP _____

OWNER Richard J. Rice ADDRESS 7070 Branch Rd. Medina, Ohio

LOCATION OF PROPERTY 7160 Hartman Rd. 500 Ft. South of Fixler Rd. West side of St.

CONSTRUCTION DETAILS

Casing diameter 5 1/2" Length of casing 28'

Type of screen _____ Length of screen _____

Type of pump sub

Capacity of pump 12 gpm

Depth of pump setting 54 ft.

Date of completion May 30, 1979

BAILING OR PUMPING TEST

(specify one by circling)

Test rate 9 gpm gpm Duration of test 3 hrs. hrs

Drawdown 35 ft Date May 28, 1979

Static level (depth to water) 24 ft. ft

Quality (clear, cloudy, taste, odor) clear no odors

Pump installed by Water well Consultants, Inc.

WELL LOG*

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Clay

0 ft

22 ft

Sand Stone

22 ft

71 ft

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.

N

Fixler Rd.

W

X

Hartman Rd.

E

S

DRILLING FIRM Water Well Consultants, Inc. DATE May 30, 1979

ADDRESS P. O. Box 120 Hinckley, Oh

SIGNED

*If additional space is needed to complete well log, use next consecutive numbered form.