

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

549794

COUNTY MEDINA TOWNSHIP WADSWORTH SECTION OF TOWNSHIP _____
OWNER LEROY BOWMAN ADDRESS WADSWORTH, OHIO
LOCATION OF PROPERTY 7800 BEAR SWAMP RD.

CONSTRUCTION DETAILS

Casing diameter 5" Length of casing 70'
Type of screen NONE Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

BAILING OR PUMPING TEST

(Specify one by circling)


Test rate 18 gpm Duration of test 2 hrs
Drawdown 45' ft Date 12/28/79
Static level (depth to water) 50' ft
Quality (clear, cloudy, taste, odor) CLEAR
Pump installed by OWNER

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
CLAY, YELLOW	0 ft	19' ft
CLAY, GRAY	19'	67'
ROCK, GRAY SAND	67'	71'
ROCK, GRAY SHALE	71'	103'
ROCK, GRAY SAND	103'	112'
ROCK, GRAY SHALE	112'	135'
ROCK, GRAY SAND	135'	139'
ROCK, GRAY SHALE	139'	147'
ROCK, GRAY SAND	147'	151'
ROCK, GRAY SHALE	151'	165'
WATER AT	150'	

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



DRILLING FIRM GEVE'S WATER SERVICE DATE 12/28/79
ADDRESS 1175 REIMER RD. SIGNED Eugene S. [Signature]
WADSWORTH, OHIO